



CONSOLIDATED COMMISSION ON UTILITIES
 Guam Power Authority | Guam Waterworks Authority
 P.O. Box 2977 Hagåtña, Guam 96932 | (671) 648-3002 | guamccu.org

GPA Resolution No. FY2024-28

Relative to Approval of the Purchase of Water Systems Diesel (WSD) Generators

WHEREAS, CCU Resolution No. FY2024-06, GPA has been approved to purchase and replace 104 generators and estimated the cost to be a total of \$9.5 million dollars;

WHEREAS, GPA issued 3 bids for the different generator sizes to mitigate potential protests;

WHEREAS, GPA bid number GPA-052-24 includes the stationary generators sizes 500 kW (7 each), 800 kW (2 each), 1,400 kW (2 each), and portable generators with trailers size 500 kW (3 each);

WHEREAS, this portion of the generator bid includes generators and installation by the vendor;

WHEREAS, the final cost of this portion of generators is \$3,177,636.33 of the estimated \$9.5 million dollars originally approved for the 104 generators;

WHEREAS, the \$3,177,636.33 portion exceeds the GPA General Manager procurement authority; and

WHEREAS, the bid committee for GPA-052-24 has evaluated the bidders and has recommended GPA procurement to award the \$3,177,636.33 to Morrico Equipment Guam, who was selected at the lowest, most responsive and responsible bidder; now, therefore, be it

RESOLVED, by the Consolidated Commission on Utilities, the governing body of the Guam Power Authority, and subject to the review and approval of the Public Utilities Commission;

RESOLVED, that the CCU authorizes the GPA General Manager to petition the Public Utilities Commission for approval to award **\$3,177,636.33** for bid number **GPA-052-24** to **Morrico Equipment Guam**, who has been selected at the lowest, most responsive and responsible bidder; and

RESOLVED, that the Chairman of the Commission certifies and the Secretary of the Commission attests to the adoption of this resolution.

DULY AND REGULARLY ADOPTED at Mangilao, Guam, this 25th day of September 2024.

Certified by:

Attested by:

Joseph T. Duenas
CHAIRPERSON

Pedro Roy Martinez
SECRETARY

SECRETARY'S CERTIFICATE

I, **Pedro Roy Martinez**, Secretary for the Consolidated Commission on Utilities, as evidenced by my signature above, do hereby certify:

The foregoing is a full, true and accurate copy of the resolution duly adopted at a regular meeting by the members of the Guam Consolidated Commission on Utilities, duly and legally held at a place properly noticed and advertised at which meeting a quorum was present and members who were present voted as follows:

 4 AYES
 0 NAYS
 1 ABSTENTIONS
 0 ABSENT



1. What is the warranty on the generators- how long and what's covered?

GPA-052-24 includes generators with installation. Warranty for the generators is below:

- *A one (1) year Warranty, to include scheduled maintenance as recommended by manufacturer, a maintenance booklet including oil and filter changes. Warranty must include all updates, diagnostic, and inspection cost for warranty assessment.*
- *Shall provide a manual listing of all warranties on entire equipment. The warranty shall begin on acceptance date delivery. To include present engine hours shall be documented on the warranty booklet.*
- *The warranty period shall be extended by adding the amount of time the equipment spends for warranty assessment and/or repairs.*

GPA-052-24 includes installation at 12 of the 14 sites (2 sites have no building). Installation warranty is below:

- *Installation shall include the connecting of generator to the facilities' existing ATS, facilities' existing fuel lines, and to the facilities' existing exhaust piping.*
- *Installation warranty shall be no less than ninety (90) days to begin upon completion of installation.*
- *The warranty period shall be extended by adding the amount of time the facility spends for installation warranty assessment and/or repairs.*
- *GPA will be responsible for ensuring the ATS and electrical are compatible with the new generators/upgrading any wiring at the site.*

2. What sites are on this list?

Table 1. GPA-052-24 large Generator Bid Site Listing.

(Names are actual names and spelling from GPA and GWA)

	WSD Station	Location	Generator Type	Generator Size (kW)
1	A-30	Agana Springs, Sinajana	Stationary	500
2	Chaligan	SD-28 Agat, Across the Agat Harbor	Stationary	500
3	Chaot New	CD-07 Ordot	Stationary	500
4	Gaan	SD-25 Agat Sewer Treatment Plant	Stationary	500
5	HGC-2	Santa Ana Housing	Mobile	500
6	HWWTP	ATP Agana Treatment Plant Hagatna	Stationary	500
7	Tai	CD-10 Tai, Mangilao Pump Station Rt.10 Near Song Market, Chalan Pago	Stationary	500
8	UGUM Wastewater Treatment Plant	Ugum Plant 1 Water Treatment Plant	Stationary	500
9	Mobile	Trailer	Mobile	500
10	Mobile	Trailer	Mobile	500
11	Fujita PS	Tumon, Fajita Road	Stationary	800
12	Ugum Plant 2	Talafofo River Plant Generator	Stationary	800

13	Route 16 Pump Station	Harmon, Route 16	Stationary	1400
14	Southern Link Pump Station	Old Coral Rd	Stationary	1400

3. Is this FEMA reimbursable?

We asked for \$10M as part of the Mitigation, but have heard no word about if FEMA will provide us this funding or any funds in advance.